

loss bulletin



Office Building Fan Flies Apart

Loss Details

| | |
|----------------------------|------------------|
| Nature of Business: | Office Building |
| Type of Equipment: | Air Handling Fan |
| Age of Equipment: | 10 years old |

FINAL LOSS

| | |
|---------------------------|--------|
| Settlement Amount: | £8,030 |
|---------------------------|--------|

At 3:00am in the morning a loud “bang” was heard from the top floor office area. Neighbours called the police who in turn called the building superintendent. Investigation revealed that a 1.5 metre diameter return fan was completely destroyed. Pieces of metal lay all over the fan’s housing chamber. This type of fan was found to no longer be in supply. A new type was needed and construction adjustments were required to the existing housing. The cause of loss is believed to be metal fatigue.

Don't leave it to chance
make sure you're protected with...



HSB Engineering Insurance Limited